

EU Declaration of Conformity (No. FSTEC18007)

In accordance with of European Parliament and Council Decision No 768/2008/EC Annex III

Product model / product:

Product Smoke Alarm Device
Model/type FireAngel SM-SN-1, FireAngel ST-230-XX, FireAngel SM-F-1XX
XX- suffix denotes country code

Manufacturer:

Name FireAngel Safety Technology Limited
Address Vanguard Centre, Sir William Lyons Road, Coventry, CV4 7EZ, UK

This declaration is issued under the sole responsibility of the manufacturer.

Object of the declaration:

Product Thermally enhanced optical smoke alarm
Specification 230V Mains with 3V Lithium non removable battery backup, 85dB(A) alarm, wall/ceiling mount

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:

305/2011/EU Construction Products Regulation
2011/65/EU The Restriction of Hazardous Substances Directive

References to the relevant harmonised standards used or references to the other technical specifications in relation to which conformity is declared:

Reference & Date	Title
EN 14604:2005+AC:2008	Smoke alarm devices
EN 50130-4:2011+A1:2014	Alarm systems - Part 4: Electromagnetic compatibility - Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems
EN 61000-6-3:2007/A1:2011 /AC:2012	Electromagnetic compatibility. Generic standards. Emission standard for residential, commercial and light industrial environments
EN60065:2014/AC:2016	Audio, video and similar electronic apparatus. Safety requirements
EN 60950-1:2006+A2:2013	Information technology equipment – Safety – Part 1: General requirements

Please refer to document **FSTDOP18001** for the Declaration of Performance for the Construction Products Regulation

Additional Information:

Signed for and on behalf of: FireAngel Safety Technology Limited
Date/Place of issue: 1st May 2018, Coventry, UK

X 

I Ballinger
Certification Manager