

## EU/UKCA Declaration of Conformity (No. 21019)

In accordance with European Parliament and Council Decision No 768/2008/EC Annex III and BS EN ISO/IEC 17050-1:2010

### 1. Product Identification:

Product Site Notification Unit

### 2. Manufacturer:

Name FireAngel Safety Technology Limited  
Address Vanguard Centre, Sir William Lyons Road, Coventry, CV4 7EZ, UK

#### EU Authorised Representative:

Name Authorised Representative Service  
Address 77 Camden Street Lower, Dublin, D02 XE80, Ireland

### 3. This Declaration of Conformity is issued under the sole responsibility of the Manufacturer

### 4. Object of the declaration:

Product Site Notification Unit  
Model/type FireAngel WRLYM-1, FireAngel WRLYM-NB  
Description Mains site notification unit with relay and RF interconnection  
Specification 230V with 6VDC battery backup (Not WRLYM-NB) with RF connection (868MHz) relays rating 250VAC/5A

### 5. The object of the declaration described above is in conformity with the relevant Union harmonisation legislation and Statutory Instruments:

### 6. Legislation and standards:

| <b>UK<br/>CA</b> UK (UKCA) Legislation  | <b>CE</b> EU (CE) Legislation                                | Designed, Harmonised and other standards showing compliance                               |
|---|--|---|
| The Radio Equipment Regulations 2017/1206 §6.1.a Safety   | The Radio Equipment Directive 2014/53/EU §3.1.a Safety       | EN 62368-1_2020+A11_2020<br>EN 62479:2010   |
| The Radio Equipment Regulations 2017/1206 §6.1.b EMC  | The Radio Equipment Directive 2014/53/EU §3.1.b EMC          | EN 50130-4:2011+A1:2014<br>EN 55022:2011+C1<br>EN 301 489-1 V2.2.3<br>EN 301 489-3 V2.1.1 |
| The Radio Equipment Regulations 2017/1206 §6.2 Spectrum   | The Radio Equipment Directive 2014/53/EU §3.2 Spectrum       | EN 300 220-2 V3.1.1   |
| The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012/3032 | The Restriction of Hazardous Substances Directive 2011/65/EU | EN IEC 63000:2018   |

### 7. Authorisation and signature

Signed for and on behalf of: FireAngel Safety Technology Limited  
Place of issue: Coventry, United Kingdom  
Date of issue: 1<sup>st</sup> November 2021  
Revision Date: 6<sup>th</sup> November 2023  
Revision: 1.02  
Name: Ian Ballinger  
Function: Head of Certification  
Signature:

