

EU/UKCA Declaration of Conformity (No. 21002)

In accordance with European Parliament and Council Decision No 768/2008/EC Annex III and BS EN ISO/IEC 17050-1:2010

1. Product Identification:

Product Domestic Smoke Alarm Device

2. Manufacturer:

Name FireAngel Safety Technology Limited
Address Vanguard Centre, Sir William Lyons Road, Coventry, CV4 7EZ, UK

EU Authorised Representative:

Name Authorised Representative Service
Address 77 Camden Street Lower, Dublin, D02 XE80, Ireland

3. This Declaration of Conformity is issued under the sole responsibility of the Manufacturer

4. Object of the declaration:

Product Smoke Alarm Device
Model/type FireAngel WST-630, AngelEye WST-AE630
Description Battery powered smoke alarm for domestic applications with RF interconnection
Specification Sealed 3V lithium, optical smoke alarm containing RF module for interconnection (868MHz)

5. The object of the declaration described above is in conformity with the relevant Union harmonisation legislation and Statutory Instruments:

6. Legislation and standards:

UK CA UK (UKCA) Legislation	CE EU (CE) Legislation	Designated, Harmonised and other standards showing compliance
<i>Construction Products Regulation (EU) No. 305/2011, as amended by The Construction Products (Amendment Etc) (EU Exit) Regulations 2019, 2020 and 2022.</i>	Construction Products Regulation 305/2011/EU	EN 14604:2005/AC2008
The Radio Equipment Regulations 2017/1206 §6.1.a Safety	The Radio Equipment Directive 2014/53/EU §3.1.a Safety	EN 62368-1_2014+A11_2017 EN 62479:2010
The Radio Equipment Regulations 2017/1206 §6.1.b EMC	The Radio Equipment Directive 2014/53/EU §3.1.b EMC	EN 50130-4:2011+A1:2014 EN 301 489-1 V2.2.3 EN 301 489-3 V2.1.1
The Radio Equipment Regulations 2017/1206 §6.2 Spectrum	The Radio Equipment Directive 2014/53/EU §3.2 Spectrum	EN 300 220-2 V3.1.1
The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012/3032	The Restriction of Hazardous Substances Directive 2011/65/EU	EN IEC 63000:2018

7. The notified body BRE Global Assurance (Ireland) Limited, DCU Alpha, Old Finglas Road, Glasnevin, Dublin, D11 KXN4, Ireland Issued the certificates 2831-CPR-F1206 in accordance with EN14604:2005+AC:2008 and 651d/12

The UK approved body BRE Global Ltd Bucknalls Lane, Watford, Hertfordshire, WD25 9XX. United Kingdom issued the certificate 0832-UKCA-CPR-F0333 in accordance with EN14604:2005+AC:2008 and 651d/12

8. Authorisation and signature

Signed for and on behalf of: FireAngel Safety Technology Limited
Place of issue: Coventry, United Kingdom
Date of issue: 1st November 2021
Revision date: 5th September 2022
Revision: 1.01
Name: Ian Ballinger
Function: Head of Certification
Signature:

