

## EU/UKCA Declaration of Conformity (No. 21025)

In accordance with European Parliament and Council Decision No 768/2008/EC Annex III and  
 BS EN ISO/IEC 17050-1:2010

### 1. Product Identification:

Product Smoke Alarm Device

### 2. Manufacturer:

Name FireAngel Safety Technology Limited  
 Address Vanguard Centre, Sir William Lyons Road, Coventry, CV4 7EZ, UK

### EU Authorised Representative:

Name Authorised Representative Service  
 Address 77 Camden Street Lower, Dublin, D02 XE80, Ireland

### 3. This Declaration of Conformity is issued under the sole responsibility of the Manufacturer

### 4. Product details:

Product Smoke Alarm Device  
 Model/type FireAngel FA6615, FA6115, FA6611, FA6111, FA6620, FA6120  
 Angeleye AE6615, AE6611, AE6620  
 Description Battery powered smoke alarm for domestic applications  
 Specification FA6620, FA6120, AE6620 (Sealed 3V Lithium battery), FA6615, FA6115, AE6615,  
 FA6611, FA6111, AE6611 ( 2 x 1.5AA replaceable Alkaline batteries) optical smoke alarm

### 5. The object of the declaration described above is in conformity with the relevant Union harmonisation legislation and UK Statutory Instruments:

### 6. Legislation and standards:

| <b>UK<br/>CA</b> UK (UKCA) Legislation   | <b>CE</b> EU (CE) Legislation                                | Designed, Harmonised and other standards showing compliance  |
|--|--|--|
| Construction Products Regulation (EU) No. 305/2011, as amended by The Construction Products (Amendment Etc) (EU Exit) Regulations 2019, 2020 and 2022. | Construction Products Regulation 305/2011/EU                 | EN14604:2005/AC:2008   |
| The Electromagnetic Compatibility Regulations 2016/1091  | The Electromagnetic Compatibility Directive 2014/30/EU       | EN 50130-4:2011+A1:2014<br>EN 61000-6-3:2007/A1:2011/AC:2012 |
| The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012/3032                                | The Restriction of Hazardous Substances Directive 2011/65/EU | EN IEC 63000:2018  |

7. The notified body CNPP - Laboratoire du Feu - Service analyse, Route de la chapelle Réanville, CS 22265, 27950 Saint Marcel 1116-CPR-151 (FA6620 / FA6120 / AE6620), 1116-CPR-152 (FA6615 / FA6115 / AE6615) and 1116-CPR-153 (FA6611 / FA6111 / AE6611) in accordance with EN14604:2005+AC:2008.

The UK approved BRE Global Ltd, Bucknalls Lane, Watford, Hertfordshire, WD25 9XX. United Kingdom issued the certificate 0832-UKCA-CPR-F1385 (FA6615), 0832-UKCA-CPR-F1386 (FA6611), 0832-UKCA-CPR-F1387 (FA6620) in accordance with EN14604:2005+AC:2008

### 8. Authorisation and signature

Signed for and on behalf of: FireAngel Safety Technology Limited  
 Place of issue: Coventry, United Kingdom  
 Date of issue: 27<sup>th</sup> January 2022  
 Revision date: 5<sup>th</sup> September 2022  
 Revision: 1.01  
 Name: Ian Ballinger  
 Function: Head of Certification  
 Signature:

