

**T** +44 (0)24 7771 7700 **E** info@fireangeltech.com **F** +44 (0)24 7669 3610 **W** fireangeltech.com

FireAngel Safety Technology Limited Vanguard Centre, Coventry CV4 7EZ, UK



## **DECLARATION OF PERFORMANCE**

No:

FSTDOP21005

**Product Name**: FireAngel SB1, Angeleye SB1-AE, FireAngel SB5, Angeleye SB5-AE

FireAngel SW1, FireAngel SW1-PF, FireAngel SW10, FireAngel SW10-PF, FireAngel SCB10, Angeleye SCB10-AE

Intended Use: Fire safety- Optical Smoke Alarm Device for residential applications

**Manufacturer:** FireAngel Safety Technology Limited

Vanguard Centre, Sir William Lyons Road

Coventry, CV4 7EZ,UK

AVCP System 1 The certification body performed type testing and the initial inspection of the manufacturing plant and of

factory production control with continuous surveillance assessment and approval of the factory production

control and issued the EC certificate of conformity

Approved Body: Intertek, Unit C, Imperial Park, Randalls Way, Leatherhead, KT22 7TA (NB 0359)

FPC Certificate: 0359-UKCA-CPR-00220 (SB1, SB1-AE, SB5, SB5-AE)

0359-UKCA-CPR-00221 (SW1, SW10) 0359-UKCA-CPR-00222 (SCB10, SCB10-AE)

| Essential Characteristics   | EN14604:2005 Clause   | Performance |
|---|---|-------------|
| Nominal activation conditions/ Sensitivity,<br>Response delay (response time) and<br>Performance under fire condition | 4.12, 4.18, 5.2, 5.3, 5.4, 5.5, 5.6, 5.15, 5.17, 5.18, 5.19, 5.20   | PASS        |
| Operational reliability   | 4.1, 4.2, 4.3, 4.4, 4.5, 4.6, 4.7, 4.8, 4.9, 4.10, 4.11, 4.13, 4.14, 4.15, 4.16, 4.17, 4.19, 5.11, 5.16, 5.22, 5.23, 5.24 | PASS        |
| Tolerance to supply voltage   | 5.21  | PASS        |
| Durability of operational reliability and response delay, temperature resistance                                      | 5.7, 5.8  | PASS        |
| Durability of operational reliability, vibration resistance   | 5.12, 5.13  | PASS        |
| Durability of operational reliability,<br>humidity resistance   | 5.9   | PASS        |
| Durability of operational reliability, corrosion resistance   | 5.10  | PASS        |
| Durability of operational reliability, electrical stability   | 5.14  | PASS        |

Note: The products covered by this standard are assumed to operate, in an event of fire, before the fire becomes so large as to affect their functioning. There is therefore no requirement to function when exposed to direct attack from fire.

Signed for and on behalf of FireAngel Safety Technology Limited

I.M.Ballinger

Head of Certification Coventry, United Kingdom

Date of Issue: 18<sup>th</sup> October 2021

Revision: 2

Revision Date: 5<sup>th</sup> September 2022

Our Brands

FireAngel. AngelEye



**T** +44 (0)24 7771 7700 **E** info@fireangeltech.com **F** +44 (0)24 7669 3610 **W** fireangeltech.com

FireAngel Safety Technology Limited Vanguard Centre, Coventry CV4 7EZ, UK

## Annex A

| Battery Operated Smoke Alarms | Battery Operated Smoke Alarms | Mains Powered Smoke Alarms |
|-------------------------------|-------------------------------|----------------------------|
|                               | and CO alarm                  |                            |
| With removeable battery       | With Sealed Battery           | With battery backup        |
| FireAngel SB1                 | FireAngel SCB10               | FireAngel SW1              |
| FireAngel SB5                 | AngelEye SCB10-AE             | FireAngel SW10             |
| AngelEye SB1-AE               |                               |                            |
| AngelEye SB5-AE               |                               |                            |
|                               |                               |                            |