

Declaration of Performance

According to Construction Products Regulation EU No 305/2011

FSTDOP19002

1. Product family:

See Annex A

2. Intended use:

Fire Safety - Thermoptek optical smoke alarm device for residential applications

3. Name, Registered Trade Name and address of Manufacturer:

FireAngel Safety Technology Limited
Vanguard Centre
Sir William Lyons Road
Coventry
CV4 7EZ
UK

EU Importer

FireAngel Safety Technology Europe B.V.
Concertgebouwplein 15 H,
1071LL Amsterdam
Netherlands

4. Declaration of Performance concerning construction product covered by harmonised standard:

EN 14604:2005+AC:2008

5. Systems or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V

System 1

6. Certified by: BRE Global Assurance (Ireland) Limited, DCU Alpha, Old Finglas Road, Glasnevin, Dublin, D11 KXN4, Ireland (NB 2831)

The certification body performed type testing and the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control and issued the EC certificate of conformity

Certificate of Constancy of Performance:

2831-CPR-F1205 (ST-630-XX, ST-AE630-XX)
2831-CPR-F1206 (WST-630-XX, WST-AE630-XX)
2831-CPR-F2598 (ST-632-XX, ST-AE632-XX)


7. Declared performance

All requirements including essential characteristics and corresponding performances for intended use or uses as described in point 2 and in accordance with essential characteristics listed in the table below (point 8). This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above

8. The performance of the products identified in points 1 and 2 are in conformity with the declared performance in point 7. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above

Essential Characteristics	EN14604:2005 Clause	Performance
Nominal activation conditions/ Sensitivity, Response delay (response time) and Performance under fire condition	4.12, 5.2, 5.3, 5.4, 5.5, 5.6, 5.15, 5.17, 5.18, 5.20	PASS
Operational reliability	4.1, 4.2, 4.4, 4.5, 4.6, 4.7, 4.9, 4.10, 4.11, 4.13, 4.15, 4.16, 4.17, 4.19, 5.11, 5.16, 5.24	PASS
Tolerance to supply voltage	5.21	PASS
Durability of operational reliability and response delay, temperature resistance	5.7, 5.8	PASS
Durability of operational reliability, vibration resistance	5.12, 5.13	PASS
Durability of operational reliability, humidity resistance	5.9	PASS
Durability of operational reliability, corrosion resistance	5.10	PASS
Durability of operational reliability, electrical stability	5.14	PASS
Note: The products covered by this standard are assumed to operate, in an event of fire, before the fire becomes so large as to affect their functioning. There is therefore no requirement to function when exposed to direct attack from fire.		

Signed



I M Ballinger
Head of Certification
Coventry, United Kingdom
Date of Issue: 16th October 2019
Revision: 1.04
Revision Date: 26th November 2024

Annex A

Sealed Battery Operated Smoke Alarms	Sealed Battery operated Smoke Alarms With RF Interlink Module
FireAngel ST-630 FireAngel ST-632 AngelEye ST-AE630 AngelEye ST-AE632	WST-630 WST-AE630