T +44 (0)24 7771 7700 E info@fireangeltech.com
F +44 (0)24 7669 3610 W fireangeltech.com
FireAngel Safety Technology, Ground Floor, BOURN,
1 Manor House Drive, Coventry, CV1 2TA, UK

EU Declaration of Conformity (No. 26002)

In accordance with European Parliament and Council Decision No 768/2008/EC Annex III

1. **Product Identification:**

Product	Multi Sensor Heat and Carbon Monoxide Alarm

2. **Manufacturer:**

Name	FireAngel Safety Technology Limited
Address	Ground Floor BOURN, 1 Manor House Drive, Coventry, CV1 2TA, UK

EU Importer:

Name	FireAngel Safety Technology Europe B.V.
Address	Concertgebouwplein 15 H, 1071LL Amsterdam, Netherlands

3. **This Declaration of Conformity is issued under the sole responsibility of the Manufacturer**

4. **Object of the declaration:**

Product	Multi Sensor Heat and Carbon Monoxide Alarm
Model/type	FireAngel FA4451BW (SP530)
Description	Mains powered Multi Sensor Heat and Carbon Monoxide Alarm for domestic applications with BLE Interlink
Specification	10 Year, 230V Mains powered with sealed primary battery backup, BLE Interlink

5. **The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:**

6. **Legislation and standards:**

CE **EU (CE) Legislation**	**Designed, Harmonised and other standards showing compliance**
The Radio Equipment Directive 2014/53/EU §3.1(a) Safety	EN 62479:2010
The Radio Equipment Directive 2014/53/EU §3.1(b) EMC	EN IEC 61000-3-2:2019 +A1:2021 +A2:2024 EN IEC 61000-3-3:2013 +A1:2019 +A2+2021 EN IEC 61000-6-3:2021 EN 50130-4:2011+A1:2014 EN 50270:2015 EN 301 489-1 V2.2.3 EN 301 489-17 V3.3.1
The Radio Equipment Directive 2014/53/EU §3.2 Spectrum	EN 300 328 V2.2.2
The Radio Equipment Directive 2014/53/EU §3.3(d) Cyber Security	EN 18031-1:2024
The Restriction of Hazardous Substances Directive 2011/65/EU	EN IEC 63000:2018

T +44 (0)24 7771 7700 E info@fireangeltech.com
F +44 (0)24 7669 3610 W fireangeltech.com
FireAngel Safety Technology, Ground Floor, BOURN,
1 Manor House Drive, Coventry, CV1 2TA, UK

7. Approved to BS 5446-2:2003 and EN 50291-1:2018 by SGS Testing & Control Services Singapore Pte Ltd, issued certificate PT/25/GEN/0730

8. **Authorisation and signature**

Signed for and on behalf of:	FireAngel Safety Technology Limited
Place of issue:	Coventry, United Kingdom
Date of issue:	24 July 2026
Revision date:	-
Revision	1.00
Name:	S J Wall
Function:	Product Certification Manager
Signature:	