T +44 (0)24 7771 7700 E info@fireangeltech.com
F +44 (0)24 7669 3610 W fireangeltech.com
FireAngel Safety Technology Limited
Vanguard Centre, Coventry CV4 7EZ, UK

DECLARATION OF PERFORMANCE

No: FSTDOP25009

Product Name: See Annex A

Intended Use: Fire safety- Optical Smoke Alarm Device for residential applications

Manufacturer: FireAngel Safety Technology Limited
Vanguard Centre, Sir William Lyons Road
Coventry, CV4 7EZ,UK

AVCP System 1 The certification body performed type testing and the initial inspection of the manufacturing plant and of factory production control with continuous surveillance assessment and approval of the factory production control and issued the EC certificate of conformity

Approved Body: BRE Global Ltd, Bucknalls Lane, Watford, Hertfordshire, WD25 9XX. United Kingdom (NB 0832)

FPC Certificate: 0832-UKCA-CPR-F1926

Essential Characteristics	EN14604:2005 Clause	Performance
Nominal activation conditions/ Sensitivity, Response delay (response time) and Performance under fire condition	4.12, 5.2, 5.3, 5.4, 5.5, 5.6, 5.15, 5.17, 5.18, 5.20	PASS
Operational reliability	4.1, 4.2, 4.5, 4.6, 4.7, 4.9, 4.10, 4.13, 4.14, 4.15, 4.16, 4.17, 4.19, 5.11, 5.16, 5.22, 5.24	PASS
Tolerance to supply voltage	5.21	PASS
Durability of operational reliability and response delay, temperature resistance	5.7, 5.8	PASS
Durability of operational reliability, vibration resistance	5.12, 5.13	PASS
Durability of operational reliability, humidity resistance	5.9	PASS
Durability of operational reliability, corrosion resistance	5.10	PASS
Durability of operational reliability, electrical stability	5.14	PASS
Note: The products covered by this standard are assumed to operate, in an event of fire, before the fire becomes so large as to affect their functioning. There is therefore no requirement to function when exposed to direct attack from fire.		

Signed for and on behalf of FireAngel safety Technology Limited

N Rutter
CEO
Coventry, United Kingdom
Date of Issue: 29th Jan 2025
Revision: 2
Date of Revision: 10th April 2025

T +44 (0)24 7771 7700 E info@fireangeltech.com
F +44 (0)24 7669 3610 W fireangeltech.com
FireAngel Safety Technology Limited
Vanguard Centre, Coventry CV4 7EZ, UK

Annex A

Battery Operated Smoke Alarms	Battery Operated Smoke Alarms
1 year Replaceable battery	5 year replaceable battery
SB1N	SB5N